



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

January 24, 2012

NYLOPLAST
ADS
SUSAN L. MCNAMEE
3130 VERONA AVE.
BUFORD GA 30518

INSERTATEE CO
NYLOPLAST
JIM FICKER
PO BOX 714
CORNELIUS OR 97113

Re: Description: FITTINGS, PVC
Manufacturer: INSERTATEE CO
Product Name: **INSERTA WYE**
Model Number(s): 4" AND 6"
Product File No: 20120031

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (5) (d) 6. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product shall be installed in accordance to the manufactures instructions.
- A wye cutting jig provided by Inserta shall be used to drill the hole in the mainline pipe.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov